

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Site: DAVES DISCO

Location: OL11 2LY

Asset ID: 124504	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544
------------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.186	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass

Overall: Pass

Asset ID: 124505	Description: MULTIBLOCK	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544
------------------	-------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.242	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass

Overall: Pass

Asset ID: 124506	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544
------------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.242	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass

Overall: Pass

Asset ID: 124507	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544
------------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.06	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass

Overall: Pass

Asset ID: 124508	Description: EXTENSION LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544
------------------	-----------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.108	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass

Overall: Pass

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Asset ID: 124509	Description: EXTENSION LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.112	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	180	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124510	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.17	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124511	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.112	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124512	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.106	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124513	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.116	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Asset ID: 124514	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
IEC Lead Polarity	18/03/2015			Pass
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.092	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124515	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.098	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124516	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.178	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124517	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.106	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124518	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.092	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Asset ID: 124519	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.116	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124520	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.068	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124521	Description: INTIMIDATOR SPOT LED 250	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.208	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124522	Description: INTIMIDATOR SPOT LED 250	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.09	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124523	Description: FUSION FX BAR	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.122	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124524	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.076	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124525	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.092	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124526	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.088	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124527	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.09	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124528	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.092	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124529	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.094	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Asset ID: 124530	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.088	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124531	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.098	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124532	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.09	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124533	Description: EZpar 64 UPLIGHTER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.084	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124534	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.048	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124535	Description: PSU	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
				Overall: Pass

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124536	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.12	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124537	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.136	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124538	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.056	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124539	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.122	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124540	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.086	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Overall: Pass				

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124541	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.142	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124542	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.054	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124543	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.12	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Asset ID: 124544	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.102	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
				Overall: Pass

Asset ID: 124545	Description: LED POWERBAR	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.104	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
				Overall: Pass

Detailed Latest Test Results

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 18/03/2015 To: 18/03/2016

Asset ID: 124546	Description: AC ADAPTOR	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124547	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.032	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124548	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.084	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Asset ID: 124549	Description: LEAD	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
IEC Lead Continuity	18/03/2015	0.054	ohm	Pass
Insulation Voltage	18/03/2015	500	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
IEC Lead Polarity	18/03/2015			Pass
Overall: Pass				

Asset ID: 124550	Description: SPEAKER	User: Admin	Test Instrument: SeawardPrimeTest 350 11D-0544	
Comments:				
Test Type	Date	Result	Unit	Status
Visual	18/03/2015			Pass
Earth Continuity	18/03/2015	0.122	ohm	Pass
Insulation Voltage	18/03/2015	250	V	Information
Insulation	18/03/2015	> 199	MOhm	Pass
Overall: Pass				

Total Tests: 47